


# Spotreba tepla rok 2008/2007

Príloha č.1

Adresa	Plocha	Spotreba			Merná spotreba			ROZ.	Porov.	Zníženie-
	celkom	UK06	UK07	UK08	UK06	UK07	UK08	2008/2007	mer.spotreby	Zvýšenie+
	m2	GJ			GJ/m2			GJ/m2	GJ/m2	%
Šupkova45/5,6	2381,76	1215,30	1209,95	1015,56	0,510	0,508	0,426	-194,390	83,934	-16,066
Šupkova46/7.8	2300,00	949,20	852,70	807,90	0,413	0,371	0,351	-44,800	94,746	-5,254
<b>Kotoliňa MS 11</b>	<b>4681,76</b>	<b>2164,50</b>	<b>2062,65</b>	<b>1823,46</b>	<b>0,462</b>	<b>0,441</b>	<b>0,389</b>	<b>-239,190</b>	<b>88,404</b>	<b>-11,596</b>
Štiavnička 203	163,90	150,26	101,14	98,58	<b>0,917</b>	<b>0,617</b>	0,601	-2,560	97,469	-2,531
<b>Štiav.33,34/204*/</b>	103,50	85,78	143,48	<b>68,64</b>	0,829	<b>1,386</b>	<b>0,663</b>	-74,840	47,839	-52,161
Štiavnička 35,36/205	662,70	267,60	299,80	234,60	0,404	0,452	0,354	-65,200	78,252	-21,748
Štiavnička 37,38/206	662,70	474,28	392,01	354,38	0,716	0,592	0,535	-37,630	90,401	-9,599
Štiavnička208	662,70	368,00	298,70	302,20	0,555	0,451	0,456	3,500	101,172	1,172
Štiavnička 43,44/209	662,70	399,90	383,30	390,70	0,603	0,578	0,590	7,400	101,931	1,931
Štiavnička 207/upr.pl./	662,70	463,09	406,10	359,10	0,699	<b>0,613</b>	0,542	-47,000	88,426	-11,574
Štiavnička 46-50/211	6981,04	2640,10	2328,90	2137,70	0,378	<b>0,334</b>	0,306	-191,200	91,790	-8,210
Štiavnička 51-54/212	5808,96	1884,10	1684,90	1519,00	0,612	<b>0,290</b>	0,261	-165,900	90,154	-9,846
<b>Kotoliňa VS 120</b>	<b>16370,90</b>	<b>6733,11</b>	<b>6038,33</b>	<b>5464,90</b>	<b>0,411</b>	<b>0,369</b>	<b>0,334</b>	<b>-573,430</b>	<b>90,504</b>	<b>-9,496</b>
TOBI:Kolk.27	1243,68	519,68	529,46	588,10	0,418	0,426	0,473	58,640	111,075	11,075
TOBII Kolk.28	1492,94	669,90	573,00	573,60	0,449	0,384	0,384	0,600	100,105	0,105
<b>TOB celkom</b>	<b>2736,62</b>	<b>1189,58</b>	<b>1102,46</b>	<b>1161,70</b>	<b>0,435</b>	<b>0,403</b>	<b>0,425</b>	<b>59,240</b>	<b>105,373</b>	<b>5,373</b>
Kolk.2,3,/2*/	397,25	0,00	0,00	0,00	0,000	0,000	0,000	0,000	0,000	*/
Kolkáreň 4,5 /3	795,50	502,45	344,56	348,64	0,632	0,433	0,438	4,080	101,184	1,184
Kolkáreň 6,7 /4	796,50	368,04	325,00	344,72	0,462	0,408	0,433	19,720	106,068	6,068
Kolkáreň 8,9 / 5	797,18	453,10	499,40	452,80	0,568	0,626	0,568	-46,600	90,669	-9,331
Kolkáreň 10,11 / 6	797,18	472,12	453,10	394,20	0,592	0,568	0,494	-58,900	87,001	-12,999
<b>Kolkáreň D - bloky</b>	<b>3583,61</b>	<b>1795,71</b>	<b>1622,06</b>	<b>1540,36</b>	<b>0,501</b>	0,453	0,430	<b>-81,700</b>	<b>94,963</b>	<b>-5,037</b>
Piesok 303				<b>237,36</b>						
<b>DALKIA a.s.</b>										
ŠLN 22,23,24,25	5995,78	1450,80	1321,56	1269	0,242	0,220	0,212	-52,56	96,023	-3,98
<b>Západ - BP</b>	<b>5995,78</b>	<b>1450,80</b>	<b>1321,56</b>	1269	<b>0,242</b>	<b>0,220</b>	<b>0,212</b>	<b>-52,56</b>	<b>96,228</b>	-3,98
Fraňa Kráľa 2	3473,61	1208,90	1106,70	1055,70	0,348	0,319	0,304	-51,00	95,390	-4,61
ŠDC 2,4	2226,96	688,92	659,20	634,31	0,309	0,296	0,285	-24,89	96,224	-3,78
Krčulova 14,16,18	4194,32	1294,80	1187,00	1207,50	0,309	0,533	0,288	20,50	101,720	1,72
Malin.20,22,24*/	4193,52	1310,20	1126,20	1085,69	0,312	0,269	0,259	-40,51	96,403	-3,60
ČSA21.23.25.27.29.31	8401,18	2261,94	2135,10	2083,51	0,269	0,444	0,248	-51,59	97,580	-2,42
<b>ŠDC - BP</b>	<b>22489,59</b>	<b>6764,76</b>	<b>6214,20</b>	<b>6066,71</b>	0,301	<b>0,276</b>	<b>0,270</b>	<b>-147,49</b>	<b>97,627</b>	<b>-2,37</b>

## Merná spotreba 2008/2007



Kotolňa	rok2007	rok2008
MS11	0,441	0,389
VS120	0,369	0,334
TOB	0,403	0,425
D bloky	0,453	0,430
Západ	0,220	0,212
ŠDC	0,276	0,270